

ZESTAWIENIE BADAŃ LABORATORYJNYCH

warstwa	próba	rodzaj gruntu	rodzaj gruntu	waleczkowanie [liczba]	ρ [g/cm ³]	I _z [%]	w _n [%]	w _p [%]	w _L [%]	I _p	I _L	I _c
		PN-86/ B02480	PN-EN ISO 14688 1									
Ib	o4/4,7	T	Or		1,16	20,2%	207,2%					
	o6/5,3	Gy	Or		1,23	18,1%	213,7%					
	o5/5,0	T	Or		1,08	29,1%	243,1%					
IIIa	o1_5,3	G π /II	siCl _{si}	3/4	1,85		20,1%	14,4%	27,8%	13,4%	0,43	0,57
	o2_3,6	G π (+H)	orclSi	3/4			43,9%	38,5%	53,20%	14,7%	0,37	0,63
IIIb	o3_5,5	G π z	siCl	4/4	1,91		29,9%	26,6%	51,20%	24,6%	0,13	0,87
IVa	o1_7,5	G	sasiCl	3/3			14,1%	10,7%	22,1%	11,4%	0,30	0,70
	o2_4,5	G	saCl	3/3	2,06		15,3%	11,2%		12,0%	0,34	0,66
	o3_8,0	Gp	clSa	2/2			14,6%	11,0%	22,30%	11,3%	0,32	0,68
IVb	o3_9,0	Pg	clSa	1/2	2,12		13,2%	11,4%		9,0%	0,20	0,80
	o6_12,0	Pg	clSa	1/2			13,0%	11,4%	20,2%	8,8%	0,18	0,82

Wyk. Tomasz Jastrzembski